

Attestation of Compliance



Reference No. : LCSA02204051S

Applicant : TIS CONTROL LIMITED

Address : FLAT/RM A 12/F ZJ 300, 300 LOCKHART ROAD, WAN CHAI, HONG KONG

Product : VALVE LIGHTING CURTAIN AIR CONDITION CONTROLLER

Trade Mark : TIS

Model(s) : VLC-12CH-10A, RLY-4CH-10A, RLY-6Ch-0-10V, ADD-3R-3A, HVAC6-5A-T, RLY-8CH-16A, RLY-8CH-10A, DIM-4CH-3A, DIM-6CH-2A, DIM-2CH-6A, TIS-FAN-CTR, MER-3R-5A, VLC-6Ch-5A, ADS-3R-BUS

Parameters : DC Input:24VDC 500mA or
Relay Input: 100-240V~ 50/60Hz 10A max.
Relay output: 100-240V~ 50/60Hz 10A max.

Tested according to : EN IEC 62368-1:2020+A11:2020

The submitted products have been tested by us with the listed standards.

This Attestation of Compliance is issued according to the council Directive 2014/35/EU, Referred to as the Low Voltage Directive. It confirms that the listed product complies with all essential requirements of the LVD Directive and applies only to the sample and its technical documentation submitted to Shenzhen LCS Compliance Testing Laboratory Ltd. for testing.

After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant Directives have to be observed.



Date of issue: March 26, 2024



Shenzhen LCS Compliance Testing Laboratory Ltd.
Room 101, 201, Building A and Room 301, Building C, Juji Industrial Park, Yabianxueziwei, Shajing Street,
Bao'an District, Shenzhen, Guangdong, China
Tel: (86)0755-82591330 Fax: (86)0755-82591332
Http://www.lcs-cert.com Email: webmaster@lcs-cert.com